

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by K. S. Rathore

(Name of Officers with designation) from AE, Khushwant Singh Rathore PHED

Inspected the St. Francis De Sales Sr. Sec. School Gindodga Neemur.

(Name & Address of the school) on 18/03/25 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no 19 dated 20/03/25

of (PHED Lab) certified that the

St. Francis De Sales Sr. Sec. School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 19/03/26

Signature with Seal: [Signature] 20/3/25
Name K. S. Rathore Assistant Engineer
Designation AE Public Health Engg. Sub Dn.
Name & Address of the Office / Department : NEEMURGH (M.P.) PHED Neemurgh

To ST. FRANCIS DE SALES
SR. SEC. SCHOOL NMH
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



District Water Testing Laboratory
Public Health Engineering Department (PHED)
Manasa Naka, Near Navgrih Shani Mandir Nee much (M.P.)

Format no: DWTL/PHED/NMH/12

Test Report

ULR No.	TC	1	3	5	4	2	2	5	0	0	0	0	0	0	1	9	F
---------	----	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

Condition of sample : OK or Not		Nature of sample: Drinking Water/ Other		Unique Identification Code.		17/NMH		Sample Not Collected by Lab <input checked="" type="checkbox"/>			
Sender's name and address: Principal St. Francis De Sales Sr. Sec. School Girdoda, Revli Devli Post, Manasa Road, Neemuch (M.P.), 458441				Quantity of sample-		1 Liter					
				Date and Time of Sampling -		05/03/2025/ 1 PM		Nature of Packaging - Glass/PPL <input checked="" type="checkbox"/>			
				Sender's letter no.		SFS/2025/022		Sender's letter Date		05/03/2025	
				DWTLNMH receipt. No.		17		DWTLNMH receipt Date		05/03/2025	
				Date of analysis started		06/03/2025		Date of analysis completed		06/03/2025	
S.no.	Block	Gram Panchayat	Village	Habitation	Location				Source		
1	Neemuch	Girdoda	Girdoda	Girdoda	St. Francis De Sales Sr. Sec. School Girdoda Revli Devli Post, Manasa Road, Neemuch (M.P.), 458441				R.O.(Well)		
Discipline : Chemical, Group : Water											
Details of parameters, their test methods, units and specifications as per BIS											
S.No.	Characteristics	Test Method	Unit	As per BIS -10500:2012 & Amendment Jan 2021 For Drinking water		Test Result					
				Requirement (Desirable Limit)	Permissible Limit in the absence of Alternate Sources	Sample Number					
1	2	3	4	5	6	1					
1	Total Hardness as CaCO ₃	IS 3025 (P-21):2009 RA 2023	mg/L	200	600	7					
2	Calcium as Ca	IS 3025 (P-40):2024 No RA	mg/L	75	200	68					
3	Magnesium as Mg	IS 3025 (P-46):2023 No RA	mg/L	30	100	12.8					
4	Total Alkalinity as CaCO ₃	IS 3025 (P-23):2023 No RA	mg/L	200	600	8.6					
5	Chloride as Cl	IS 3025 (P-32):1988 RA 2019	mg/L	250	1000	45					
6	Colour	IS 3025 (P-04) :2021 No RA	Hazen	5	15	27					
7	Turbidity	IS 3025 (P-10) :2023 No RA	NTU	1.0	5.0	0					
8	pH @25°C	IS 3025 (P-11) : 2022 No RA	pH scale	6.5 to 8.5	6.5 to 8.5	0.1					
9	Sulphate as SO ₄	IS 3025 (P-24) : 2022 No RA	mg/L	200	400	7.46					
10	Conductivity @25°C	IS 3025 (P-14) : 2013 RA 2023	µmhos/cm	-	-	5.9					
11	Total Dissolve Solids @180°C	IS 3025 (P-16) :2023 No RA	mg/L	500	2000	122					
12	Odour	IS 3025 (P-5) : 2018 RA 2022	-	Agreeable	Agreeable	80					
13	Taste	IS 3025 (P-8) : 2023 No RA	-	Agreeable	Agreeable	Agreeable					
14	Fluoride as F-	IS 3025 (P-60) : 2023 No RA	mg/L	1.0	1.5	Agreeable					
						0.11					

Specific Information:

1. This report shall not be produced partly or full without written Permission of laboratory.
2. Samples will be stored for a period of 05 days from the date of issue of report.
3. This laboratory does not hold any responsibility for variation in results for samples kept on hold.
4. Results relate only to the items tested and the sample as Received.
5. Collection of sample from the source "This Information is provided by the Customers only" and laboratory will not responsible for such information.

Issue no. 19 /DWTL/PHED/NMH/ /2025 Issue Date: 20/03/2025

End of Report
Page 1 of 1

Reviewed By
Pooja Malviya
(Quality Manager)
Authorized Signatory
District Water Testing Laboratory (M.P.)
Neemuch (M.P.)

District Water Testing Laboratory
Public Health Engineering Department PHED
Manasa Naka, Near Navgrih Shani Mandir Neemuch (M.P.)

Sender's Letter No.: SFS/2025/022		Date: 05/03/2025		DWTL Receipt No. 17		DWTL Receipt Date: 05/03/2025		Unique Identification Code. 17/NMH	
Physical and Chemical Test Report with details of Parameters, their Test methods, Units and Specifications as per BIS									
S.No	Characteristics	Test Method	Unit	As per BIS -10500:2012 & Amendment Jan 2021 For Drinking water		Test Results			
				Requirement (Desirable Limit)	Permissible Limit in the absence of Alternate Sources	Sample Numbers			
						1			
15	Nitrate as No ₃	PDA Method, Based on std. Method 1960& NEERI Manual 2012	Mg/l	45	45	4.77			
16	Iron as Fe	IS 3025 (P-53) : 2024 No RA	Mg/l	1.0	1.0	0.07			
17	Manganese as Mn	IS 3025 (P-59) : 2023 No RA	Mg/l	0.1	0.3	0.00			
18	Arsenic	By Kit	Mg/l	0.01	0.01	0.00			
19	Residual Chlorine as Cl ₂	By Visual/ Comparative method	Mg/l	0.2	1.00	0.0			
Bacteriological Test Report With Details of their Test Methods, Units and Specifications as per BIS									
S.No	Characteristics	Test Method	Unit	As per BIS -10500:2012 & Amendment Jan 2021 For Drinking water		Test Results			
				Requirement (Desirable Limit)	Permissible Limit in the absence of Alternate Sources	Sample Numbers			
						1			
1	Total Coliform	APHA 23 rd Edition	Per 100ml	NIL		0			
2	Faecal Coliform(TTC)	APHA 23 rd Edition	Per 100ml	NIL		0			

Remarks (if Any)-


 Pooja Malviya
 Quality Manager
 Authorized Signatory
 District Water Testing Laboratory Neemuch(M.P.)
 District Water Testing Laboratory
 Neemuch (M.P.)